# **Energy performance certificate (EPC)**

32 Rainsford Road CHELMSFORD CM1 2QG Energy rating

D

Valid until: 21 December 2027

Certificate number: 9790-5927-0383-7090-2014

Property type B1 Offices and Workshop businesses


Total floor area 365 square metres

# Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

## **Energy rating and score**

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

### How this property compares to others

Properties similar to this one could have ratings:

If newly built	24 A
If typical of the existing stock	69 C

## Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	68.15
Primary energy use (kWh/m2 per year)	394

# **Recommendation report**

Guidance on improving the energy performance of this property can be found in the <u>recommendation report (/energy-certificate/9571-4099-0238-0290-0775)</u>.

#### Who to contact about this certificate

#### Contacting the assessor

Date of assessment

Date of certificate

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Ray Hutchins
Telephone	0789 2681 495
Email	ray.epc@gmail.com

Contacting the accreditation scheme
If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd	
Assessor's ID	EES/019803	
Telephone	01455 883 250	
Email	enquiries@elmhurstenergy.co.uk	
About this assessment		
Employer	Benchmark Surveys	
Employer address	Croft, Tenpenny Hill, Thorrington, Colchester. CO7 8JG	
Assessor's declaration	The assessor is not related to the owner of the property.	

30 November 2017

22 December 2017